

**Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu**

**The Principal
Army Public School
Damana**

No: JDJF&ES/FP/ 7039

Dated: 01.11.2022

Sub: Provisional Fire Safety Certificate.


Ref: Your online application submission dated:- 30.09.2022.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguishers in their school premises. The school is about 2½ Km away from Fire and Emergency Station Canal (Muthi) and is approachable for fire appliances in case of any emergency. As such the management can proceed ahead for operation provisionally subject to adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:-

1. 01 No. of CO₂ Type fire extinguisher of 4.5 Kg each capacity should be provided near each main electric switch board panel in addition to already existing fire extinguishers.
2. Hose Reel Hoses as per BIS specifications connected with the terrace tank of 5000 Ltrs. capacity should be provided in the school building. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of school building are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near terrace water storage tank with dual electric supply for feeding the Hose Reel Hoses.
3. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
4. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. The corridor of the building shall not be used for any kind of storage.
7. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this provisional clearance issued will be treated automatically withdrawn/cancelled.
8. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
9. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is triple storey. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/cancelled.
11. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
12. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
13. The validity of this provisional clearance shall remain in force for six months and same needs to be renewed after checking of fire fighting system installed in the school (i.e. existing as well as proposed).

Yours faithfully



**Joint Director
Fire & Emergency Services
Jammu Range, Jammu**

